


VIEW $\frac{A}{200}$
ACCESS PANEL FOR INSPECTION OF FILL



TERMINATION POINTS

- 01-HOT WATER INLETS
- 02-COLD WATER OUTLETS
- 03-DRAIN OUTLET
- 04-OVERFLOW CONNECTION
- 05-MAKE-UP WATER CONNECTION
- 06-QUICK FILL CONNECTION

- 2 x 100NB FLANGE TABLE E AS.2129
- 2 x 200NB CUTOUT (TABLE AS.2129)
- 50NB CUTOUT (TABLE E AS.2129)
- 50NB BSP FEMALE
- 20NB BSP MALE
- 20NB BSP MALE

WEIGHTS

- DRY- 1850 Kg
- OPERATING-5000 Kg

REV.	DESCRIPTION	DRAWN	CHECKED	APPROVED	ISSUE DATE
5	-	-	-	-	-
4	-	-	-	-	-
3	-	-	-	-	-
2	REVISION 2	-	-	-	1.05.2000
1	QUICK FILL CONNECTION ADDED	B.S.	B.S.	B.S.	26.05.98
0	ORIGINAL ISSUE	C.S.	B.S.	B.S.	18.07.96

GENERAL NOTES:
DO NOT SCALE
ALL DIMENSIONS IN MILLIMETRES
GENERAL TOLERANCE UNLESS OTHERWISE STATED LINEAR ± 5 , ANGULAR -

SUPERCHILL Australia
 1000 GPO Box 999
 Sydney NSW 1585
 Tel: (02) 9739 5732 Fax: (02) 9739 1888

CLIENT	-	CONTRACT No.	-
LOCATION	-	JOB No.	-
EQUIPMENT	EWK 900	DWG. REPLACED BY	-
CAD FILE No.	EWK 0900	DWG. REPLACES	900 100 001
SCALE	N.T.S.	SEP. PARTS LIST	NO

TITLE	EWK 900 COOLING TOWER DIMENSION SHEET	DRAWN	C.S.
PLANT	COOLING TOWER	CHECKED	B.C.
DWG. No.	EWK 0900	APPROVED	P.E.
DATE	18.07.96	SHEET SIZE	A3
REV.	2		