



WEIGHT

DRY 480 KG
WET 1045 KG

MOTOR

3 KW 6 POLE FOOT MTD
TEFC 415-3-50

IMPELLER

1150/3-3/PPG/6WR/27.5°

TERMINATION POINTS

N1-HOT WATER INLET NB100 (FLANGE)-PVC
N2-QUICK FILL NB20 BSP (M)-BRASS
N3-MAKE UP WATER NB20 (M)-BRASS
N4-OVERFLOW NB32 BSP (F)-PVC
N5-COLD WATER OUTLET NB125 (FLANGE)-PVC
N6-DRAIN NB50

GENERAL NOTES:
-DO NOT SCALE
-ALL DIMENSIONS IN MILLIMETERS
-GENERAL TOLERANCE UNLESS OTHERWISE STATED.
LINEAR + 5, ANGULAR + 1°

SUPERCHILL

Superchill Australia Pty Limited
200 Princes Hwy
Bass Point NSW 2217
Australia
Tel: 018 939 0362 Fax: 018 939 2000

CLIENT	NA	CONTRACT No.	NA	TITLE	SC115 COOLING TOWER GENERAL ARRANGEMENT	DRAWN	B.S.
LOCATION	NA	JOB No.	004	PLANT	NA	CHECKED	B.S.
EQUIPMENT	NA	DWG. REPLACES	NA	DRG. No.	SC115004	APPROVED	B.S.
CAD FILE No.	SC115	SEP. PARTS LIST	NO	SCALE	1:25	DATE	9/7/98
PROJECT	SC115					SHEET	1
						SIZE	A3
						REV	1

5					
4					
3					
2					
1					
0	ORIGINAL ISSUE				
REV.	DESCRIPTION	DRAWN	CHECKED	APPROVED	ISSUE DATE
1					
2					
3					
4					