



VIEW **A** 200 REMOVABLE ACCESS PANEL OPTIONAL

FAN MOTOR

INSPECTION DOOR
600 x 500 SS

M-PACK AIR INTAKE LOUVRES
ON ALL FOUR SIDES

TERMINATION POINTS

- 01-HOT WATER INLET
- 02-COLD WATER OUTLET
- 03-DRAIN OUTLET
- 04-OVERFLOW CONNECTION
- 05-MAKE-UP WATER CONNECTION

- 2 x 100NB FLANGE TABLE E AS.2129
- 200NB CUT OUT TABLE AS.2129 (second outlet if flow > 135 m3/h)
- 50NB CUT OUT TABLE E AS.2129
- 50NB BSP FEMALE
- 20NB BSP MALE

WEIGHTS
 DRY- 1400 Kg
 OPERATING- 4700Kg

GENERAL NOTES:
 -DO NOT SCALE
 -ALL DIMENSIONS IN MILLIMETRES
 -GENERAL TOLERANCE UNLESS OTHERWISE STATED: LINEAR ±5, ANGULAR ±1°

SUPERCHILL AUSTRALIA PTY LTD
 All 079 750 000
 200 Wharfway
 Geelong VIC 3216
 Fax 053 5763 6188 New 053 9755 0200

CLIENT	XXX	CONTRACT NO.		TITLE	EWK 630 COOLING TOWER DIMENSION SHEET	DRAWN	BS
LOCATION	XXX	JOB NO.				CHECKED	BS
EQUIPMENT	XXX	DWG. REPLACED BY	BS			APPROVED	BS
CAD FILE NO.	EWK630	DWG. REPLACES	0630200	PLANT	COOLING TOWER	DATE	19/7/99
SCALE	NTS	SEF. PARTS LIST	NO	DWG NO.	EWK630	SHEET SIZE	A3
						REV	2

5	-				
4	-				
3	-				
2	-				
1	SUPERCHILL TITEL	BS	BS	BS	19/7/99
0	ORIGINAL ISSUE	BS	BS	BS	19/7/99
REV.	DESCRIPTION	DRAWN	CHECKED	APPROVED	ISSUE DATE